



SECTION B
NOT TO SCALE 708

NOTES:

1. 8" PRV STATION SHOWN. 6" PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6".
2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
3. ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.
4. SET COVER SLAB FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET COVER SLAB APPROX. 2" ABOVE FINISHED GRADE IF LOCATED IN LANDSCAPING AREA.

APPROVED: WILLIAM J. CAMPBELL

REV. DATE: JULY 01, 2007

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**6" AND 8" PRV
STATION SECTION**

FILE SD709B.DGN DRAWING NO. **709B**